



Customer Advice Notice

Revision

To: CAN NZ Participants
Sent: 08-mar-2026 19:17
Ref: 7209663295

From: The System Operator
Telephone: 0800 488 500
Email: NMDData@transpower.co.nz

Revision of: **CAN, 7208118841, 08-mar-2026 08:50, Change to Shoulder ratings from 15-Mar-2017 07:00 to 10-May-2017 06:59**

Change to Shoulder ratings from 15-Mar-2026 07:00 to 10-May-2026 06:59

The System Operator has been advised by the Grid Owner of the following change:

Effective 07:00 on the 15th March ~~2017~~ 2026 and continuing through until 06:59 on 10th May ~~2017~~ 2026, shoulder ratings will apply for the following:

Grid transmission circuit ratings (except those circuits having Variable Line Ratings).

Note that for each day of the period that shoulder ratings apply:

- Shoulder day ratings will apply from 07:00 to 20:59
- Shoulder night (winter) ratings will apply from 21:00 to 06:59

The circuits with Variable Line Ratings and therefore not affected by this change to shoulder ratings are: Atiamuri Ohakuri 1, Atiamuri Whakamaru 1, Blackpoint Tee Oamaru 1, Glenavy Oamaru 2, Otahuhu Hautapu Tee Whakamaru 1 & 2, Kawarau Matahina 1 & 2, Kinleith Lichfield Tarukenga 1 & 2, and Ohakuri Wairakei 1.

With the exception of the Redclyffe interconnectors, interconnecting transformer seasonal ratings will remain on summer ratings and will be applied daily until 06:59 10th May ~~2022~~ 2026 as follows:

- Summer day ratings will apply from 07:00 to 20:59
- Winter ratings will apply from 21:00 to 06:59

Summer ratings will apply to all trading periods for the Redclyffe interconnecting transformers during the shoulder and summer rating periods.

...