



TRANSPOWER



Customer Advice Notice

Revision

To: CAN NZ Participants**Sent:** 04-may-2025 15:37**Ref:** 6238531178**From:** The System Operator**Telephone:** 0800 488 500**Email:** NMData@transpower.co.nz**Revision of: CAN, 6235301811, 03-may-2025 12:08, Planned Outage****Cause:** Planned Outage**Outage/At:** HVDC Pole 3**Starting:** ~~04-may-2025 12:00~~ 04-may-2025 12:00**Ending:** ~~04-may-2025 16:00~~ 04-may-2025 16:30 Continuous

Transpower advises HVDC Pole 3 will be unavailable during the above times to clean HV equipment at the cable termination stations exposed to salt contamination during recent severe weather to restore insulation properties. Pole 2 will remain in service.

HVDC capacity during this outage will be:

Asset	North capacity	South capacity
HVDC Pole 2	500 MW	489 MW
HVDC Pole 3	0 MW	0 MW

Round power will be disabled during this outage, preventing HVDC reserve sharing in the reverse power direction below the monopole minimum transfer.

Frequency Keeping Control (FKC) will be disabled for trading periods in which the scheduled HVDC transfer is close to the monopole minimum. No SIR sharing is modelled when FKC is disabled.

The system operator business process for disabling and enabling FKC during HVDC monopole operation is described on the Transpower website at the following link:

<https://www.transpower.co.nz/system-operator/information-industry/frequency-keeping-control-fkc-information>

No CAN will be issued updating the status of FKC for the duration of the work.

A revision of this notice will be issued if there is any change to the situation above.

A revision of this notice will be issued if there is any change to the situation above.