



TRANSPOWER



Customer Advice Notice

To: CAN NZ Participants

Sent: 19-aug-2025 10:45

Ref: 6558301335

From: The System Operator

Telephone: 0800 488 500

Email: NMData@transpower.co.nz

Revision of:

Transmission Circuit Risk Reclassification

Transpower as System Operator advises that the loss of:

- Huapai - Marsden 1 and Bream Bay - Huapai 1 is being managed as a single event

Reason	Time
Electrical storm	10:30 19/08/2025 to 12:30 19/08/2025

System splits have been created on Henderson - Maungatapere 1 and Henderson - Maungatapere 2 at Maungatapere circuit breakers 252 and 292.

This notice is in accordance with The Policy Statement, Clause 12.4. For more information please refer to the following Transpower webpage:

<https://www.transpower.co.nz/system-operator/resources-asset-owners/risk-double-circuit-faults>

...

A revision of this notice will be issued if there is any change to the situation above.