



TRANSPOWER



Excursion Notice

To: SO Notice South Island Participants

From: The System Operator

Sent: 08-may-2026 17:19

Telephone: 0800 488 500

Ref: 800000117

Email: NMData@transpower.co.nz

Revision of:

Excursion: Voltage

Time: 08-may-2026 17:11

Location: South Island

Affected Plant: Multiple Trippings, Hokitika Otira 2 Tripped, Hokitika Kumara 1 Tripped

SI Hz Level:

NI Hz Level:

Comments: Loss of supply to Hokitika

A revision of this notice will be issued if there is any change to the situation above.