



TRANSPOWER



Excursion Notice

To: Excursion NZ Participants
Sent: 04-feb-2026 20:38
Ref: 7099654833

From: The System Operator
Telephone: 0800 488 500
Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency
Time:	04-feb-2026 20:30
Location:	National
Affected Plant:	Benmore Haywards 1 Tripped
SI Hz Level:	51.03
NI Hz Level:	49.20
Comments:	

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.