



TRANSPOWER



Excursion Notice

To: SO Notice NZ Participants

From: The System Operator

Sent: 23-aug-2026 12:07

Telephone: 0800 488 500

Ref: 800000331

Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency		
Time:	23-aug-2026 11:24		
Location:	National		
Affected Plant:	Multiple Trippings, Brydone Edendale 1 Tripped, Edendale Invercargill 1 Tripped, Invercargill North Makarewa 1 Tripped, Invercargill Tiwai 1 Tripped, Kaiwera Gore North Makarewa 1 Tripped, Manapouri Generation Tripped, North Makarewa Gore Three Mile Hill 2 Tripped, North Makarewa T1 Tripped, North Makarewa T2 Tripped, North Makarewa Tiwai 1 Tripped, North Makarewa Tiwai 2 Tripped		
SI Hz Level:	48.072	NI Hz Level:	49.174
Comments:	Loss of supply to Brydone, Edendale and North Makarewa		

Frequency Excursion notices are only issued if the deviation is outside 49.5.and 50.5 Hz.