



TRANSPOWER



Excursion Notice

To: Excursion NZ Participants
Sent: 23-oct-2025 18:16
Ref: 6758545974

From: The System Operator
Telephone: 0800 488 500
Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency		
Time:	23-oct-2025 17:42		
Location:	National		
Affected Plant:	Tauhara Generation Tripped, Te Huka 3 Generation Tripped		
SI Hz Level:	49.31	NI Hz Level:	49.20
Comments:			

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.