



Excursion Notice

To: Excursion NZ Participants
Sent: 29-mar-2026 02:23
Ref: 7280030395

From: The System Operator
Telephone: 0800 488 500
Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency		
Time:	29-mar-2026 02:12		
Location:	National		
Affected Plant:	Tiwai Reduction Line		
SI Hz Level:	51.21	NI Hz Level:	50.59
Comments:	Tiwai Reduction Line Tripped		

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.