



Excursion Notice

To: SO Notice NZ Participants

From: The System Operator

Sent: 19-may-2026 02:52

Telephone: 0800 488 500

Ref: 800000137

Email: NMDData@transpower.co.nz

Revision of:

Excursion: Frequency

Time: 19-may-2026 02:40

Location: National

Affected Plant: Tiwai Reduction Line

SI Hz Level: 50.76

NI Hz Level: 50.51

Comments:

Frequency Excursion notices are only issued if the deviation is outside 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.