



TRANSPOWER



Excursion Notice

To: Excursion NI Participants
Sent: 13-feb-2026 18:26
Ref: 7129942658

From: The System Operator
Telephone: 0800 488 500
Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency
Time:	13-feb-2026 18:11
Location:	North Island
Affected Plant:	Maraetai Whakamaru 1 Tripped
SI Hz Level:	NI Hz Level: 50.55
Comments:	

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.