



TRANSPOWER



Excursion Notice

To: SO Notice South Island Participants

From: The System Operator

Sent: 19-sept-2026 23:02

Telephone: 0800 488 500

Ref: 800000378

Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency
Time:	19-sept-2026 22:53
Location:	South Island
Affected Plant:	Multiple Trippings, Invercargill Tiwai 1 Auto-reclosed, Invercargill Tiwai 2 Auto-reclosed, Tiwai Reduction Line Tripped
SI Hz Level:	50.67
NI Hz Level:	
Comments:	

Frequency Excursion notices are only issued if the deviation is outside 49.5.and 50.5 Hz.