



TRANSPOWER



Excursion Notice

To: Excursion SI Participants
Sent: 23-oct-2025 07:56
Ref: 6757406723

From: The System Operator
Telephone: 0800 488 500
Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency		
Time:	23-oct-2025 07:45		
Location:	South Island		
Affected Plant:	Islington Kikiwa 1 Tripped		
SI Hz Level:	50.53	NI Hz Level:	
Comments:	Loss of Supply to the Upper South Island.		

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.