



TRANSPOWER



## Excursion Notice

**To:** Excursion SI Participants  
**Sent:** 27-jan-2026 20:11  
**Ref:** 7072613516

**From:** The System Operator  
**Telephone:** 0800 488 500  
**Email:** NMData@transpower.co.nz

### Revision of:

<b>Excursion:</b>	Frequency
<b>Time:</b>	27-jan-2026 20:05
<b>Location:</b>	South Island
<b>Affected Plant:</b>	Manapouri Generation Tripped
<b>SI Hz Level:</b>	49.49
<b>NI Hz Level:</b>	
<b>Comments:</b>	

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.