



Excursion Notice

To: Excursion SI Participants
Sent: 25-feb-2026 06:29
Ref: 7169050177

From: The System Operator
Telephone: 0800 488 500
Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency	
Time:	25-feb-2026 05:51	
Location:	South Island	
Affected Plant:	Pole 3 South Blocking.	
SI Hz Level:	49.50	NI Hz Level:
Comments:		

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.