



TRANSPOWER



## Excursion Notice

**To:** Excursion SI Participants  
**Sent:** 14-jul-2025 14:33  
**Ref:** 6449591726

**From:** The System Operator  
**Telephone:** 0800 488 500  
**Email:** NMData@transpower.co.nz

**Revision of:**

<b>Excursion:</b>	Frequency		
<b>Time:</b>	14-jul-2025 14:29		
<b>Location:</b>	South Island		
<b>Affected Plant:</b>	Tiwai Reduction Line		
<b>SI Hz Level:</b>	50.57	<b>NI Hz Level:</b>	
<b>Comments:</b>			

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.