



TRANSPOWER



Excursion Notice

To: Excursion SI Participants
Sent: 12-aug-2025 14:06
Ref: 6537240979

From: The System Operator
Telephone: 0800 488 500
Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency		
Time:	12-aug-2025 14:01		
Location:	South Island		
Affected Plant:	Tiwai Reduction Line		
SI Hz Level:	50.54	NI Hz Level:	
Comments:			

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.