



TRANSPOWER



Excursion Notice

To: Excursion SI Participants
Sent: 18-aug-2025 12:40
Ref: 6555157995

From: The System Operator
Telephone: 0800 488 500
Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency		
Time:	18-aug-2025 12:22		
Location:	South Island		
Affected Plant:	Tiwai Reduction Line		
SI Hz Level:	50.61	NI Hz Level:	
Comments:			

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.