



TRANSPOWER



## Excursion Notice

**To:** Excursion SI Participants  
**Sent:** 04-dec-2025 15:02  
**Ref:** 6892151033

**From:** The System Operator  
**Telephone:** 0800 488 500  
**Email:** NMData@transpower.co.nz

**Revision of:**

|                        |                      |                     |  |
|------------------------|----------------------|---------------------|--|
| <b>Excursion:</b>      | Frequency            |                     |  |
| <b>Time:</b>           | 04-dec-2025 14:52    |                     |  |
| <b>Location:</b>       | South Island         |                     |  |
| <b>Affected Plant:</b> | Tiwai Reduction Line |                     |  |
| <b>SI Hz Level:</b>    | 50.73                | <b>NI Hz Level:</b> |  |
| <b>Comments:</b>       |                      |                     |  |

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.