



Excursion Notice

To: Excursion SI Participants
Sent: 08-jan-2026 08:54
Ref: 7009649923

From: The System Operator
Telephone: 0800 488 500
Email: NMDATA@transpower.co.nz

Revision of:

| | |
|------------------------|----------------------|
| Excursion: | Frequency |
| Time: | 08-jan-2026 08:49 |
| Location: | South Island |
| Affected Plant: | Tiwai Reduction Line |
| SI Hz Level: | 50.55 |
| Comments: | NI Hz Level: |

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.