



Excursion Notice

To: Excursion SI Participants
Sent: 08-jan-2026 09:12
Ref: 7009952863

From: The System Operator
Telephone: 0800 488 500
Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency
Time:	08-jan-2026 09:07
Location:	South Island
Affected Plant:	Tiwai Reduction Line
SI Hz Level:	50.56
Comments:	NI Hz Level:

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.