



# Excursion Notice

**To:** Excursion SI Participants

**Sent:** 15-jan-2026 00:37

**Ref:** 7031585215

**From:** The System Operator

**Telephone:** 0800 488 500

**Email:** NMDATA@transpower.co.nz

## Revision of:

**Excursion:** Frequency

**Time:** 15-jan-2026 00:31

**Location:** South Island

**Affected Plant:** Tiwai Reduction Line

**SI Hz Level:** 50.73

**NI Hz Level:**

**Comments:**

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.