



Excursion Notice

To: SO Notice South Island Participants

From: The System Operator

Sent: 11-jun-2026 05:45

Telephone: 0800 488 500

Ref: 800000172

Email: NMData@transpower.co.nz

Revision of:

Excursion: Frequency

Time: 11-jun-2026 05:40

Location: South Island

Affected Plant: Tiwai Reduction Line

SI Hz Level: 50.56

NI Hz Level:

Comments:

Frequency Excursion notices are only issued if the deviation is outside 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.