



TRANSPOWER



Excursion Notice

To: SO Notice South Island Participants

From: The System Operator

Sent: 12-sept-2026 04:05

Telephone: 0800 488 500

Ref: 800000365

Email: NMData@transpower.co.nz

Revision of:

Excursion: Frequency

Time: 12-sept-2026 03:58

Location: South Island

Affected Plant: Tiwai Reduction Line

SI Hz Level: 50.59

NI Hz Level:

Comments:

Frequency Excursion notices are only issued if the deviation is outside 49.5.and 50.5 Hz.