



TRANSPOWER



Excursion Notice

To: SO Notice South Island Participants

From: The System Operator

Sent: 17-sept-2026 08:59

Telephone: 0800 488 500

Ref: 800000376

Email: NMData@transpower.co.nz

Revision of:

Excursion: Frequency

Time: 17-sept-2026 08:52

Location: South Island

Affected Plant: Tiwai Reduction Line

SI Hz Level: 50.54

NI Hz Level:

Comments:

Frequency Excursion notices are only issued if the deviation is outside 49.5.and 50.5 Hz.