Excursion Notice

To:	SO Notice South Island Participants	**From:**	The System Operator
Sent:	11-nov-2026 20:59	**Telephone:**	0800 488 500
Ref:	800000461	**Email:**	NMData@transpower.co.nz

Revision of:

Excursion:	Frequency		
Time:	11-nov-2026 20:55		
Location:	South Island		
Affected Plant:	Tiwai Reduction Line		
SI Hz Level:	50.61	**NI Hz Level:**	
Comments:			

Frequency Excursion notices are only issued if the deviation is outside 49.5.and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.