



TRANSPOWER



## Excursion Notice

**To:** SO Notice South Island Participants

**From:** The System Operator

**Sent:** 02-jun-2026 05:31

**Telephone:** 0800 488 500

**Ref:** 800000155

**Email:** NMData@transpower.co.nz

**Revision of:**

<b>Excursion:</b>	Frequency	
<b>Time:</b>	02-jun-2026 05:21	
<b>Location:</b>	South Island	
<b>Affected Plant:</b>	Tiwai Reduction Line Tripped	
<b>SI Hz Level:</b>	50.66	<b>NI Hz Level:</b>
<b>Comments:</b>		

Frequency Excursion notices are only issued if the deviation is outside 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.