



Excursion Notice

To: SO Notice South Island Participants

From: The System Operator

Sent: 23-jun-2026 13:31

Telephone: 0800 488 500

Ref: 800000190

Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency	
Time:	23-jun-2026 13:24	
Location:	South Island	
Affected Plant:	Tiwai Reduction Line Tripped	
SI Hz Level:	50.54	NI Hz Level:
Comments:		

Frequency Excursion notices are only issued if the deviation is outside 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.