



TRANSPOWER



Excursion Notice

To: SO Notice South Island Participants

From: The System Operator

Sent: 12-sept-2026 04:56

Telephone: 0800 488 500

Ref: 800000367

Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency		
Time:	12-sept-2026 04:51		
Location:	South Island		
Affected Plant:	Tiwai Reduction Line Tripped		
SI Hz Level:	50.51	NI Hz Level:	
Comments:			

Frequency Excursion notices are only issued if the deviation is outside 49.5.and 50.5 Hz.