



Excursion Notice

To: Excursion SI Participants, Excursion NI Participants
Sent: 09-apr-2026 04:26
Ref: 7316992145

From: The System Operator
Telephone: 0800 488 500
Email: NMData@transpower.co.nz

Revision of:

Excursion:	Frequency/Voltage		
Time:	09-apr-2026 04:17		
Location:	National		
Affected Plant:	Tiwai Reduction Line		
SI Hz Level:	50.77	NI Hz Level:	50.50
Comments:			

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.