



TRANSPOWER



Excursion Notice

To: Excursion SI Participants

Sent: 27-oct-2025 23:32

Ref: 6770432464

From: The System Operator

Telephone: 0800 488 500

Email: NMData@transpower.co.nz

Revision of:

Excursion: Frequency/Voltage

Time: 27-oct-2025 23:28

Location: South Island

Affected Plant: Manapouri Generation Tripped

SI Hz Level: 49.47

NI Hz Level:

Comments:

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.