



TRANSPOWER



## Excursion Notice

**To:** Excursion SI Participants

**Sent:** 08-oct-2025 13:01

**Ref:** 6713735475

**From:** The System Operator

**Telephone:** 0800 488 500

**Email:** NMData@transpower.co.nz

**Revision of:**

**Excursion:** Frequency/Voltage

**Time:** 08-oct-2025 12:56

**Location:** South Island

**Affected Plant:** Tiwai Reduction Line

**SI Hz Level:** 50.58

**NI Hz Level:**

**Comments:**

Frequency Excursion notices are only issued if the deviation is out side 49.5 and 50.5 Hz.

A revision of this notice will be issued if there is any change to the situation above.