



TRANSPOWER



Excursion Notice

To: SO Notice North Island Participants

From: The System Operator

Sent: 04-aug-2026 20:07

Telephone: 0800 488 500

Ref: 800000278

Email: NMData@transpower.co.nz

Revision of:

Excursion: Frequency/Voltage

Time: 04-aug-2026 19:45

Location: North Island

Affected Plant:

SI Hz Level: **NI Hz Level:** 49.24

Comments: Huntly generation tripped

Frequency Excursion notices are only issued if the deviation is outside 49.5.and 50.5 Hz.