



TRANSPOWER



## Excursion Notice

**To:** SO Notice NZ Participants

**From:** The System Operator

**Sent:** 06-jun-2026 19:46

**Telephone:** 0800 488 500

**Ref:** 800000165

**Email:** NMDData@transpower.co.nz

**Revision of:**

**Excursion:** Voltage

**Time:** 06-jun-2026 19:37

**Location:** North Island

**Affected Plant:**

**SI Hz Level:**

**NI Hz Level:**

**Comments:** Otahuhu Hautapu Whakamaru 2 Auto-Reclosed, Hautapu T2 Tripped.

A revision of this notice will be issued if there is any change to the situation above.