Excursion Notice

To:	SO Notice North Island Participants	**From:**	The System Operator
Sent:	07-nov-2026 16:11	**Telephone:**	0800 488 500
Ref:	800000445	**Email:**	NMData@transpower.co.nz

Revision of:

Excursion:	Voltage
Time:	07-nov-2026 16:07
Location:	North Island
Affected Plant:	
Comments:	Albany Wairau Rd 3 Tripped

A revision of this notice will be issued if there is any change to the situation above.