



# Excursion Notice

**To:** Excursion NI Participants  
**Sent:** 25-apr-2026 13:24  
**Ref:** 7376272867

**From:** The System Operator  
**Telephone:** 0800 488 500  
**Email:** NMData@transpower.co.nz

**Revision of:**

<b>Excursion:</b>	Voltage
<b>Time:</b>	25-apr-2026 13:18
<b>Location:</b>	North Island
<b>Affected Plant:</b>	Bunnythorpe Paraparaumu Haywards 1 Auto-reclosed, Paraparaumu T1 Auto-reclosed
<b>Comments:</b>	Commutation failure of HVDC Pole 2 &3

A revision of this notice will be issued if there is any change to the situation above.