



TRANSPOWER



Excursion Notice

To: Excursion NI Participants
Sent: 15-jul-2025 11:32
Ref: 6451995838

From: The System Operator
Telephone: 0800 488 500
Email: NMData@transpower.co.nz

Revision of:

| | |
|------------------------|--|
| Excursion: | Voltage |
| Time: | 15-jul-2025 11:24 |
| Location: | North Island |
| Affected Plant: | Edgumbe Waiotahi 2 Auto-reclosed |
| Comments: | Te Herenga O Te Ra generation tripped. |

A revision of this notice will be issued if there is any change to the situation above.