Excursion Notice

To:	SO Notice North Island Participants	**From:**	The System Operator
Sent:	06-nov-2026 13:56	**Telephone:**	0800 488 500
Ref:	800000428	**Email:**	NMData@transpower.co.nz

Revision of:

Excursion:	Voltage
Time:	06-nov-2026 13:40
Location:	North Island
Affected Plant:	Henderson Maungatapere 1 Auto-reclosed, Maungaturoto T1 Tripped

Comments:

A revision of this notice will be issued if there is any change to the situation above.