



TRANSPOWER



Excursion Notice

To: SO Notice North Island Participants

From: The System Operator

Sent: 26-may-2026 15:12

Telephone: 0800 488 500

Ref: 800000149

Email: NMDData@transpower.co.nz

Revision of:

Excursion:	Voltage
Time:	26-may-2026 15:08
Location:	North Island
Affected Plant:	Kaikohe Maungatapere 1 Auto-reclosed
SI Hz Level:	NI Hz Level:
Comments:	Ngawha B Generation Tripped

A revision of this notice will be issued if there is any change to the situation above.