



TRANSPOWER



Excursion Notice

To: SO Notice North Island Participants

From: The System Operator

Sent: 30-may-2026 14:36

Telephone: 0800 488 500

Ref: 800000152

Email: NMData@transpower.co.nz

Revision of:

Excursion:	Voltage
Time:	30-may-2026 14:26
Location:	North Island
Affected Plant:	National Park T1 Tripped
SI Hz Level:	NI Hz Level:
Comments:	Loss of supply to National Park

A revision of this notice will be issued if there is any change to the situation above.