



TRANSPOWER



Excursion Notice

To: SO Notice South Island Participants

From: The System Operator

Sent: 07-jun-2026 12:38

Telephone: 0800 488 500

Ref: 800000167

Email: NMData@transpower.co.nz

Revision of:

Excursion:	Voltage
Time:	07-jun-2026 12:26
Location:	South Island
Affected Plant:	Blenheim Kikiwa 1 Auto-reclosed
SI Hz Level:	NI Hz Level:
Comments:	Loss of Argyle generation

A revision of this notice will be issued if there is any change to the situation above.