Excursion Notice

To:	SO Notice South Island Participants	**From:**	The System Operator
Sent:	05-nov-2026 22:54	**Telephone:**	0800 488 500
Ref:	800000427	**Email:**	NMData@transpower.co.nz

Revision of:

Excursion:	Voltage
Time:	05-nov-2026 22:46
Location:	South Island
Affected Plant:	Coleridge Otira 1 Auto-reclosed
Comments:	Momentary loss of supply to Castle Hill and Arthur's Pass.

A revision of this notice will be issued if there is any change to the situation above.