



TRANSPOWER



Excursion Notice

To: Excursion SI Participants

Sent: 27-nov-2025 10:21

Ref: 6868611207

From: The System Operator

Telephone: 0800 488 500

Email: NMData@transpower.co.nz

Revision of:

Excursion:	Voltage
Time:	27-nov-2025 10:14
Location:	South Island
Affected Plant:	Coleridge Otira 1 Tripped
Comments:	Loss of supply to Castle Hill and Arthur's Pass.

A revision of this notice will be issued if there is any change to the situation above.