



TRANSPOWER



Excursion Notice

To: Excursion SI Participants

Sent: 10-jul-2025 11:15

Ref: 6437717487

From: The System Operator

Telephone: 0800 488 500

Email: NMData@transpower.co.nz

Revision of:

Excursion: Voltage

Time: 10-jul-2025 11:05

Location: South Island

Affected Plant: Dobson Reefton Inangahua 2 Auto-reclosed, Reefton T3 Tripped

Comments:

A revision of this notice will be issued if there is any change to the situation above.