



TRANSPOWER



## Excursion Notice

**To:** Excursion SI Participants

**Sent:** 20-dec-2025 19:30

**Ref:** 6947262292

**From:** The System Operator

**Telephone:** 0800 488 500

**Email:** NMData@transpower.co.nz

**Revision of:**

**Excursion:** Voltage

**Time:** 20-dec-2025 19:21

**Location:** South Island

**Affected Plant:** Islington Waipara Culverden Kikiwa 3 Auto-reclosed

**Comments:** Kikiwa CB 322 Tripped

A revision of this notice will be issued if there is any change to the situation above.