



## Excursion Notice

**To:** Excursion SI Participants  
**Sent:** 11-jan-2026 05:42  
**Ref:** 7019265540

**From:** The System Operator  
**Telephone:** 0800 488 500  
**Email:** NMData@transpower.co.nz

### Revision of:

<b>Excursion:</b>	Voltage
<b>Time:</b>	11-jan-2026 05:38
<b>Location:</b>	South Island
<b>Affected Plant:</b>	Multiple Trippings, Cromwell Frankton 1 Auto-reclosed, Cromwell Frankton 2 Auto-reclosed, Frankton T1 Tripped, Frankton T3 Tripped
<b>Comments:</b>	

A revision of this notice will be issued if there is any change to the situation above.