



TRANSPOWER



## Excursion Notice

**To:** Excursion SI Participants

**Sent:** 04-oct-2025 13:54

**Ref:** 6701010864

**From:** The System Operator

**Telephone:** 0800 488 500

**Email:** NMData@transpower.co.nz

**Revision of:**

<b>Excursion:</b>	Voltage
<b>Time:</b>	04-oct-2025 13:48
<b>Location:</b>	South Island
<b>Affected Plant:</b>	Stoke 66kV Feeders Tripped
<b>Comments:</b>	Loss of supply to Stoke 66kV.

A revision of this notice will be issued if there is any change to the situation above.