



TRANSPOWER



Excursion Notice

To: SO Notice South Island Participants

From: The System Operator

Sent: 04-jun-2026 20:44

Telephone: 0800 488 500

Ref: 800000163

Email: NMData@transpower.co.nz

Revision of:

Excursion:	Voltage
Time:	04-jun-2026 20:36
Location:	South Island
Affected Plant:	Multiple Trippings, Stoke Feeder Tripped
SI Hz Level:	NI Hz Level:
Comments:	Loss of supply to Stoke 66kV

A revision of this notice will be issued if there is any change to the situation above.