



TRANSPOWER



REPORT

Grid Emergency Report

To: GEN NZ Participants

Sent: 21-apr-2026 00:17

Ref: 7359456842

From: The System Operator

Telephone: 0800 488 500

Email: NMData@transpower.co.nz

Revision of:

Grid Emergency Notice ref:

Cause: Asset exceeding advised limit

At: Edgecumbe

Starting: 20-apr-2026 20:15

Ending: 21-apr-2026 00:00

Action Taken: Grid reconfiguration Owhata circuit breaker 112 opened, due to lightning in the Bay of Plenty area.

This notice is issued in accordance with Clause 13.101, Part 13

A revision of this notice will be issued if there is any change to the situation above.