



TRANSPOWER



REPORT

Grid Emergency Report

To: GEN NZ Participants

Sent: 13-nov-2025 04:13

Ref: 6822069074

From: The System Operator

Telephone: 0800 488 500

Email: NMData@transpower.co.nz

Revision of:

Grid Emergency Notice ref: 6820244262

Cause:	Severe (G4) Geomagnetic Induced Current Event.
At:	South Island
Starting:	12-nov-2025 14:45
Ending:	13-nov-2025 04:00
Action Taken:	A Grid Emergency was declared to remove the following assets from service due to the onset of an severe (G4) Geomagnetic Induced Current event; South Island Circuits: Roxburgh – Three Mile Hill circuit 1 North Makarewa – Gore – Three Mile Hill circuit 1 Benmore – Twizel circuit 1 Roxburgh T10

This notice is issued in accordance with Clause 13.101, Part 13

A revision of this notice will be issued if there is any change to the situation above.