



TRANSPOWER



REPORT

Grid Emergency Report

To: GEN NZ Participants

Sent: 12-jun-2023 09:32

Ref: 4823615185

From: The System Operator

Telephone: 0800 488 500

Email: NMData@transpower.co.nz

Revision of:

Grid Emergency Notice ref:

Cause: Unplanned outage Bombay

At: Bombay

Starting: 12-jun-2023 07:21

Ending: 12-jun-2023 07:30

Action Taken: Grid Emergency declared for restoration of Bombay following unplanned tripping of Bombay T5 during a planned outage of Bombay T4, Bombay-Hamilton 1 and Arapuni- Bombay 1.

This notice is issued in accordance with Clause 13.101, Part 13

A revision of this notice will be issued if there is any change to the situation above.